

VOC Content Test Certificate

Friday, January 14th, 2011

Manufacturer: Chemisys Australia Pty Ltd (PO BOX 3604, Loganholme, QLD, 4129)

Sample Description: Cutek Green Batch 251110A

Tested: December 2010

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Cutek Green
Other Solvent-Based coatings 200 grams per Litre as VOC content material	139 grams per Litre as VOC content material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Cutek Green
Other Solvent-Based coatings 200 grams per Litre as VOC content material	139 grams per Litre as VOC content material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1012-01